

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 2545-0270:102 Page 1 of 1

CATEGORY: Operable Partitions

LISTEE: Modernfold, 512 Fifth Street NW, Dyersville, IA 52040
Contact: Tom Goldsmith *(563) 875-7136

DESIGN: ACOUSTI-SEAL Models 931, 941, 932, 942, 933, 933E, 923E, and 934 folding partitions.
Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	PRODUCT	FLAME SPREAD	SMOKE DEVELOPMENT
	Barrister 18 oz (water)	5	5
	Barrister 18 oz (solvent)	10	10
	Barrister 30 oz (water)	10	30
	Barrister 30 oz (solvent)	15	40
	Embossed Vinyl 18 oz	10	10
	Embossed Vinyl 30 oz	15	45
	Woodgrain 15 oz	10	5
	Woodgrain 30 oz	5	20
	Style 3912 Fabric 8.6 oz	10	10
	Style 3924 Fabric 9.7 oz	15	10
	Style 3925 Fabric 12.2 oz	10	5
	Tufted Loop 15 oz	15	25

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and CSFM label.

APPROVAL: Listed as folding partitions where Class I flame spread is required.

NOTE: Only the flame spread of the finishes were examined.

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager